



Dominion

DAM INSPECTION CHECKLIST **POSSUM POINT POWER STATION** **POND ABC**

INSPECTION DATE: 02/23/15 (0930)

WEATHER: OVERCAST; 33°F; WIND 10-15 mph

INSPECTED BY: Jeff MARCELL

Location/ Condition	(y/n)	Change (y/n)	Comments
Low Point, A dike*			
Flow	N	N	SNOW COVER; SOME STANDING WATER BEHIND SAND BAGS
Erosion	N	N	SNOW COVER ON SAND BAGS & REP-RAP
Low Point, B dike*			
Flow	N	N	SNOW COVER; NO STANDING WATER
Erosion	N	N	SNOW COVER ON SAND BAGS & REP-RAP
Outfall			
water surface El. (top of stoplogs to water)			63.5"; NO STANDING WATER BEHIND WEIR; NO DRILL; NO SEEPING; SNOW COVER AROUND WEIR

* See figure below.

Additional Comments (Note any changes observed along the embankment crest or downstream slope observed from the crest.): APPROX. 4"-5" OF SNOW ON 02/21 THAT CHANGED TO LIGHT RAIN

HIGH TIDE @ 1028

